



### TEST REPORT

Sample / Report No.	TH/ M/12/09/140		
Name of Customer	M/S DALAL ENGINEERING PVT. LTD.		
Address of Customer	Kavasar Thane - Ghodbunder Road Thane - 400 607.		
Order / Reference	Ref.No.: 011158 Dated : 21.12.2009		
Nature of Sample	Borewell Water Sample		
Sample Drawn by	Customer	Sample Received On	21/Dec/2009
Start Of Analysis	21/Dec/2009	End Of Analysis	24/Dec/2009
Sample Container	Plastic	Sample Quantity	1000 ml
Limits	As per IS 10500 : 2003		

Parameters	Results	Limits	Units	Method
<b>Microbiological Test</b>				
Total Coliforms	23	<10	Org / 100ml	IS 1622
Escherichia coli	Present	Absent	per100 ml	IS 1622
Remark	C	--	--	--

NOTE : C - Contaminated

*M. Pathak*  
M. P. Pathak  
QA Officer - TM

*R. R. Amritkar*  
R. R. Amritkar  
Director

This report can not be reproduced in parts .

Page 1 of 1